

TAMBARAM FIRE AND RESCUE SERVICES

NO OBJECTION CERTIFICATE

LICENSE NO: 178/V/TBM/2026
C.R.NO : 499/V/TBM/2026

DATE :16.07.2026

Subject: Fire and rescue service department – Tambaram Fire and Rescue Service Station for purpose of no objection certificate – REG.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date : 14.09.2004
(2) G.O. No.123 School Edu (2) Dept, Date : 14.09.2004
(3) Date of Requisition letter from THE PRINCIPAL,
SRI CHAITANYA TECHNO SCHOOL, Dated: 13.07.2026.

Based on the Govt. order mentioned above and the requisition letter given by the SRI CHAITANYA TECHNO SCHOOL, at S.NO.71/7A1E&45, 72/1A3,1B1,1B2,1D2,1E2,1E3, 1E8,1E9,1E10,1E11,1E12,1E13,1F1,1F2, RAJIV GANDHI STREET, THIRUVANCHERI VILLAGE, SELAIYUR, CHENNAI-600 126. Tamil Nadu the building and premises comprises requisition letter given SRI CHAITANYA TECHNO SCHOOL Running in a GROUND+TWO FLOORS ONLY have complied with the fire prevention and fire safety requirements accordance with rule of state fire services rules and verified on 16.07.2026 in the presence of Principal and that the building premises is fit for occupancy up to classes **NURSERY** to grade **XII** school is granted NOC from 16.07.2026 to 15.07.2027 and subject to the conditions stated below.

THIS CERTIFICATE DOES NOT VALID FOR SWIMMING POOL IN THAT PREMISES AREA.

THE ABOVE PREMISES INSPECTED BY STATION OFFICER FIRE& RESCUE SERVICES STATION ,G.TAMILPANDI ON 16/07/2026.



B. Ravi Kumar

B. Ravi Kumar
STATION OFFICER
FIRE AND RESCUE SERVICE
TAMBARAM STATION, CHENNAI-600 047

For SREE MURAGAN EDUCATIONAL TRUST

Sri Chaitanya
PRINCIPAL

To:

THE PRINCIPAL ,
SRI CHAITANYA TECHNO SCHOOL,
S.NO.71/7A1E&45, 72/1A3,1B1,1B2,1D2,1E2,1E3, 1E8,1E9,1E10,
1E11,1E12,1E13,1F1,1F2, RAJIV GANDHI STREET,
THIRUVANCHERI VILLAGE, SELAIYUR, CHENNAI-600 126.

MANAGER

Sri Chaitanya T School
No.72,Rajiv G Street,
Thiruvanchery, Selaiyur
Ph: 72079 98387 98387

CONDITIONS

1. Fire Safety Systems should be maintained in good working condition.
2. Mock Drill to be conducted periodically with the help of local fire brigade.
3. Any erection of permanent or Temporary structure should be intimated to this department.
4. A trained Fire Service Person, preferably retired one should be appointed.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are instead.
 - a) Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.
 - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
 - d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
 - e) Mock drill has to be conducted at regular intervals in consultation with the District Fire Officer, Fire and Rescue Services, South Chennai District at AshokNagar, Chennai-600083.
 - f) The classrooms should always be in the ground floor upto 3rd standards.
 - g) The classroom doors/ windows should be made of either non combustible material or materials with high fire-resistance rating.
 - h) The class room doors / windows shall always open outwards.
 - i) The class room doors/windows shutters when opened should not obstruct movement along the exit or escape route.
 - j) A Class room shall have two entrances. One door with opening towards the teachers and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside.
 - k) This door shall not have any arrangement for locking from outside.
 - l) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.

If here is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.



For SREE MURAGAN EDUCATIONAL TRUST

B. Ravikumar

MANAGER

Srinivasan D

PRINCIPAL

Sri Chaitanya Techno School
No.72, Rajiv Gandhi Street,
Thiruvanchery, Selaiyur, Chennai - 600126
Tel: 70070 00206 / 70070 00287

D. D. Rajinikanth
STATION OFFICER
FIRE AND RESCUE SERVICE
TAMBARAM STATION, CHENNAI-600 047